

## ACCESSIBILITY CHECKLIST



### PARKING

Yes    No    N/A

1. If parking is provided, is at least 1 per 25 spaces reserved for accessible parking?			
2. Are accessible parking spaces at least 96" wide with access aisle along side an additional 60" wide, with appropriate eye-level sign?			
3. Is at least 1 of 8 accessible parking space "van accessible" with 96" wide access aisle and appropriate eye-level sign?			
4. Easy wheelchair access from parking space to sidewalk?			



### ACCESS ROUTE (to get to entrance, common areas, etc.)

Yes    No    N/A

1. Are all parts of facility connected by access routes that are at least 36" wide (except doors), have steps no more than 1/2" high, and clear of protruding objects between 27" and 80" from ground?			
2. Ramps and cutaways: Slope does not exceed 1:12* and at least 36" wide? Ramps longer than 6' must have railings 34"-38" high, and uninterrupted slope cannot exceed 30'. A ramp that is 30' or more requires a 5' x 5' area for passage and resting.			



### ENTRANCE & INTERIOR DOORS; ELEVATORS

Yes    No    N/A

1. Is there clear signage to the accessible entrance?			
2. Hinged, not revolving, easy-opening doors with at least a 32" clear opening?			
3. Are all thresholds no higher than 3/4" with beveled edge, and a slope no greater than 1:2?			
4. If there are ELEVATORS: wheelchair accessible and serving all levels not ramped?			
5. Car controls no higher than 48", closed fist operable and marked with raised characters and both visual and audible floor indicators?			



### COMMON AREAS (INTERIOR AND EXTERIOR)

Yes    No    N/A

1. Are all the appropriate accommodations and facilities of your business usable by persons with disabilities, with 36" wide accessible routes free of protrusions from 27" to 80" high?			
2. Where seating is at tables, is clearance 19" deep, 27" high, 30" wide, with adequate space between people seated at tables (32" minimum) for wheelchair passage, in a reasonable proportion of the common area? Alternatives are available to fixed seating.			
3. At the bar, is clearance 19" deep, 27" high, 30" wide, with adequate space between people seated at the bar (32" minimum) for wheelchair passage, in a reasonable proportion of the common area? Alternatives are available to fixed seating.			
4. Is a portion of the service counter spaces no more than 36" high, or is there lower space to the counter's side (minimum: 36" wide)?			



### PUBLIC RESTROOMS AND DRINKING FOUNTAINS

Yes    No    N/A

1. If there are public restrooms, does at least one per floor have at least a 32" door?			
2. Is there unobstructed space 5' x 5' (including the sink and toilet)? If a stall is provided, is it 5' x 5'?			
3. Are there grab bars at the back and side of the toilet?			
4. Are fixtures reachable from a seated position, and operable with a closed fist?			
5. If drinking fountains are provided, is one spout no higher than 36"?			



### OUTDOOR DINING FACILITIES

Yes    No    N/A

1. Spaces are in compliance with the "Common Areas" portion of this form.			
2. Are picnic areas and shelters located on an accessible route -- level, non-slip surface, with tables at least 30" wide (with extended end at least 19" from table legs and clearance height)?			